

TECHNICAL REPORT

التقرير الفني

PRODUCT	Accessories - Control Units	منتج
PRODUCT APPLICATION	Fire Detection and Alarm System	تصنيف المعدة
APPLICANT / P.O BOX	ابج تردينغ اند كونتركتينغ	مقدم الطلب
MANUFACTURER / LOCATION	Axess Power SRL / ITALY	الشركة المصنعة / بلد الصنع

الوصف

الموديل

Valve Regulated, Lead Acid batteries, Sealed Maintenance Free Capacity, 3.3Ah, Voltage, 12Vdc; Rated Capacity @10Hr (Ah) at 25C	AP12-3.3
Valve Regulated, Lead Acid batteries, Sealed Maintenance Free Capacity, 5.0Ah, Voltage, 12Vdc; Rated Capacity @10Hr (Ah) at 25C	AP12-5
Valve Regulated, Lead Acid batteries, Sealed Maintenance Free Capacity, 7.0Ah, Voltage, 12Vdc; Rated Capacity @10Hr (Ah) at 25C	AP12-7
Valve Regulated, Lead Acid batteries, Sealed Maintenance Free Capacity, 9.0Ah, Voltage, 12Vdc; Rated Capacity @10Hr (Ah) at 25C	AP12-9
Valve Regulated, Lead Acid batteries, Sealed Maintenance Free Capacity, 12Ah, Voltage, 12Vdc; Rated Capacity @10Hr (Ah) at 25C	AP12-12
Valve Regulated, Lead Acid batteries, Sealed Maintenance Free Capacity, 17Ah, Voltage, 12Vdc; Rated Capacity @10Hr (Ah) at 25C	AP12-17

3RD PARTY CERTIFICATE / APPROVAL	BAZR2.MH66397	UNDERWRITERS LABORATORIES (UL)	شهادة المختبرات المساندة (من هيئات معتمدة)
----------------------------------	---------------	--------------------------------	---

RECOMMENDATIONS	التوصيات
-----------------	----------

Notes:

1.This product approval shall comply with the Design, Inspection, Installation, Testing and Maintenance requirements of NFPA 111 (and/or other related NFPA Codes / Standards), other acceptable International Codes / Standards, Local Regulations, Listing Instructions and/or Manufacturer's Published Instructions subject to the technical review and approval of the Authority Having Jurisdiction / Qatar Civil Defence.

2.The basic standard used to investigate products in this category is ANSI/UL 1989, "Standby Batteries."

الإدارة العامة للدفاع المدني

عبدالله بن  
مدير ادارة الوقاية  
الإدارة العامة للدفاع المدني

